



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2101647R1

Socket-outlet

Type designation: EGSz2pzFAR/.., EGSz2pzFR/.., EGSz2SpzFAR/.., EGSz2SpzFR/.., EGSz2SpzFARL/..

Certificate holder: Kontakt-Simon S.A
ul Bestwinska 21
Czechowice-Dziedzice 43-500
POLAND

The product complies with the standard(s): IEC 60884-1:2002+A1+A2
SS 428 08 34:2013+T1
NEK 502:2016

Date of expiry: 13 December, 2026

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:  **Date:** 17 February, 2022

Henrik Wikström

APPENDIX:

Reference No. SE-S-2101647R1

Technical Data:

Type designation	EGSz2pzFAR/.., EGSz2pzFR/.., EGSz2SpzFAR/.., EGSz2SpzFR/.., EGSz2SpzFARL/..,
Rated voltage (V)	250~
Rated current (A)	16
Conductor area	1.5 / 2.5
Standard sheet	III
Trademark	simon
Test Report	2025595STO-003
Product information	Double socket-outlets 16A, 250V~ with protecting earth, flush-type, with shutters, IP20. EGSz2pzFAR screw terminals, for 60mm box EGSz2pzFR screw terminals, for 11/2 box EGSz2SpzFAR screwless terminals, for 60mm box. EGSz2SpzFR screwless terminals, for 11/2-box. EGSz2SpzFARL screwless terminals, for 60mm box, with divided phase contact For rigid and flexible conductors.

Manufacturing Sites:

Kontakt-Simon S.A
ul Bestwinska 21
Czechowice-Dziedzice 43-500
Poland

This certificate replaces previously issued ref. No. SE-S-2101647 dated 13 December 2021. A new certificate has been issued on account of addition of three socket-outlets.

Certification Body:

Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:



Date: 17 February, 2022

Henrik Wikström